



announcements 4/24/08

A3: Envelope Heat Transfer

References: Available by this weekend (course website)

Due next week

Lecture: Tonight, 6:30 in Kane Hall, Room 210

Lars Gemzøe Architect MAA, Associate Partner, Gehl Architects, Copenhagen, Denmark

Global Green: A lecture/panel series showcasing Danish and Pacific Northwest Sustainable Planning and Design: "PLACES FOR PUBLIC LIFE: WINNING BACK PUBLIC SPACE AROUND THE WORLD."



Assigned Readings by Section (not page)

ON RESERVE
caup library


9th Edition
Chapter 4
Thermal Properties of Building and Insulations Materials (beginning on page 147)



IN REFERENCE
caup library

10th Edition
Appendix E
Thermal Properties of Building and Assemblies (beginning on page 1547)





1. ENVELOPE UA

$$U \times A$$

BTU/hr ft² °F x ft²

2. INFILTRATION "UA"

$$VHC_{air} \times Volume \times ACH$$

0.18 BTU/ft³ °F x ft³ x no./hr

3. PERIMETER "UA"

$$F \times P$$

(BTU/hr ft °F) x (ft)

STEP 1: Envelope Heat Transfer Coefficient (UA conduction)					
Building Element	U-value (BTU/hr ft ² °F)	Area (sf)	U x Area (BTU/hr °F)	Description	
Roof					
Roof Deck					
Roof Ins.					
Roof Mem.					
Roof Fin.					
Wall					
Wall C					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					
Wall N					
Wall S					
Wall E					
Wall W					

SERIES HEAT TRANSFER

	k conductivity BTU-in hr-ft ² -°F	C Conductance BTU hr-ft ² -°F	R Resistance hr-ft ² -°F BTU	Path 1 (insulation) hr-ft ² -°F BTU	Path 2 (framing) hr-ft ² -°F BTU
outside air film					
1/2" wood siding		1.24			
1/2" medium density particleboard					
5-1/2" fiberglass batt insulation					
5-1/2" wood framing (Douglas Fir)					
1/2" gypsum board					
inside air film					

R_s total

Paths 1 & 2

Overall R-value of Walls & Ceiling

Overall U-value of Walls & Ceiling

STEP 1: Envelope Heat Transfer Coefficient (UA conduction)

Building Element Orientation	Element	U-value BTU/hr ft ² °F	Area ft ²	U x Area BTU/hr °F	Description
South	Door C				
	Window D				
	Door 4				
	Windows E (2)				
	Door 5				
East	Walls				
	Window C				
	Doors 6				
	Door 2				
North	Walls				
	Windows A (3)				
	Window B				
	7 Window				
West	8 Window				
	3 Door				
	Walls				
Ceiling/Roof	Window C				
	Ceiling/Roof				

UA conduction

Determining UA

Step 2: Infiltration (convective heat transfer)

$$Q = .018 \times V_{air} \times ACH \times \Delta T$$

Q = heat loss or gain
 .018 = volumetric heat capacity of air (BTU/ft³ °F)
 ACH = air changes per hour
 V_{air} = volume of air (ft³)
 ΔT = T_{inside} - T_{outside}

STEP 2: Infiltration Heat Loss ("UA" infiltration)

Volumetric Heat Capacity (Air)	0.018	BTU/ft ³ °F
Building Volume (ft ³)	9216	ft ³
Air Changes per Hour (ACH)	1.30	ACH

"UA" infiltration = VHC x Volume x ACH

$$216 \text{ BTU/hr } ^\circ\text{F}$$

Farnsworth House
UA_{ref}

Building Element Orientation	Element	U-value BTU/hr ft ² °F	Area ft ²	U x Area BTU/hr °F	Description
South	Walls, Doors and Windows	1.124	384	432	
	Walls, Doors and Windows	1.124	192	216	
North	Walls, Doors and Windows	1.124	384	432	
	Walls, Doors and Windows	1.124	192	216	
Ceiling/Roof	Walls, Doors and Windows	0.158	1152	182	
	Walls, Doors and Windows	0.112	1152	129	
Walls, Doors and Windows					

UA conduction = 1696 BTU/hr °F

STEP 2: Infiltration Heat Loss ("UA" infiltration)

Volumetric Heat Capacity (Air)	0.018	BTU/ft ³ °F
Building Volume (ft ³)	9216	ft ³
Air Changes per Hour (ACH)	1.30	ACH

"UA" infiltration = VHC x Volume x ACH

$$216 \text{ BTU/hr } ^\circ\text{F}$$

STEP 3: Perimeter Heat Loss ("UA" perimeter)

Heat loss coefficient (F)	0.14	BTU/hr ft °F
Length of building perimeter (P)	10	ft

"UA" perimeter = F x P

$$14 \text{ BTU/hr } ^\circ\text{F}$$

UA_{perimeter} = 1822 BTU/hr °F

Note: Step 3, "UA" perimeter, is not applicable since the Farnsworth House is not built with the floor in contact with the earth.

If the Farnsworth House was built with a slab-on-grade or a basement condition, the **Perimeter Heat Loss** would have to be considered (Step 3) as follows:

Step 3: Perimeter
for slab-on-grade or basement conditions - not applicable to the Farnsworth House

$$Q = F \times P \times \Delta T$$

F = empirically derived constant
(Table E.11, pg. I582)
 P = length of perimeter (ft)
 ΔT = T_{inside} - T_{outside}




Table E.12

TABLE E.12 Heat Flow Coefficients (F_s) for Slab-on-Grade Floors with Various Insulation Strategies

R-Value, Position, and Width (or Depth) of Insulation	F _s	
	(Btu/h ft ² °F)	(W/m ² K)
Uninsulated slab	0.73	1.26
R-5 (SI: R-0.88) Horizontal insulation, 2 ft (0.6 m), no thermal break	0.70	1.21
R-10 (SI: R-1.76) Horizontal insulation, 2 ft (0.6 m), no thermal break	0.70	1.21
R-15 (SI: R-2.64) Horizontal insulation, 2 ft (0.6 m), no thermal break	0.69	1.19
R-5 (SI: R-0.88) Horizontal insulation, 4 ft (1.2 m), no thermal break	0.67	1.16
R-10 (SI: R-1.76) Horizontal insulation, 4 ft (1.2 m), no thermal break	0.64	1.11
R-15 (SI: R-2.64) Horizontal insulation, 4 ft (1.2 m), no thermal break	0.63	1.09
R-5 (SI: R-0.88) Vertical insulation, 2 ft (0.6 m)	0.58	1.00
R-10 (SI: R-1.76) Vertical insulation, 2 ft (0.6 m)	0.54	0.93
R-15 (SI: R-2.64) Vertical insulation, 2 ft (0.6 m)	0.52	0.90
R-5 (SI: R-0.88) Vertical insulation, 4 ft (1.2 m)	0.54	0.93
R-10 (SI: R-1.76) Vertical insulation, 4 ft (1.2 m)	0.48	0.83
R-15 (SI: R-2.65) Vertical insulation, 4 ft (1.2 m)	0.45	0.78
R-10 (SI: R-1.76) Fully insulated slab (insulated under entire slab as well as around edge)	0.36	0.62

Source: Super Good Cents Heat Loss Reference, Vol. 1, Ecotope Group, for Bonneville Power Administration, 1988. Insulation is extruded polystyrene, R = 5.0 h ft² °F/Btu-in. (SI: R = 34.7 m² K/W). Soil conductivity is 0.75 Btu/h ft °F (1.30 W/m K). No thermal break at edge of slab, where so indicated. If a thermal break is provided with horizontal insulation, use the corresponding value for vertical insulation. Values assume an unheated slab (as per data in Table A-16 of ANSI/ASHRAE/IESNA Standard 90.1-2001, Energy Standard for Buildings Except Low-Rise Residential Buildings); F_s values increase substantially when slab is heated.

Table E.11

TABLE E.11 Heat Loss Coefficients (F_s) for Slab-on-Grade Floors

Construction*	Insulation	R-Value (SI)		F _s (SI)	
		2000	1980	2000	1980
M Block wall, R = 0.05	Uninsulated	0.62	0.69	1.07	1.17
1/2" R-10 edge to footer	Extruded polystyrene	0.48	0.61	0.84	0.89
1/2" R-10 edge to footer	Polystyrene	0.60	0.64	0.81	0.85
1/2" R-10 edge to footer	Polystyrene	0.67	0.64	0.81	0.85
1/2" R-10 edge to footer	Polystyrene	0.75	0.72	0.78	0.82
1/2" R-10 edge to footer	Polystyrene	0.83	0.80	0.76	0.80
1/2" R-10 edge to footer	Polystyrene	0.91	0.88	0.74	0.78
1/2" R-10 edge to footer	Polystyrene	1.00	0.97	0.71	0.75
1/2" R-10 edge to footer	Polystyrene	1.10	1.07	0.68	0.72
1/2" R-10 edge to footer	Polystyrene	1.20	1.17	0.65	0.69
1/2" R-10 edge to footer	Polystyrene	1.30	1.27	0.62	0.66
1/2" R-10 edge to footer	Polystyrene	1.40	1.37	0.59	0.63
1/2" R-10 edge to footer	Polystyrene	1.50	1.47	0.56	0.60
1/2" R-10 edge to footer	Polystyrene	1.60	1.57	0.53	0.57
1/2" R-10 edge to footer	Polystyrene	1.70	1.67	0.50	0.54
1/2" R-10 edge to footer	Polystyrene	1.80	1.77	0.47	0.51
1/2" R-10 edge to footer	Polystyrene	1.90	1.87	0.44	0.48
1/2" R-10 edge to footer	Polystyrene	2.00	1.97	0.41	0.45

Source: Adapted with permission of the American Society of Heating, Refrigerating and Air Conditioning Engineers, Inc. from 1988 ASHRAE Handbook Fundamentals. The authors do not assume any responsibility for the accuracy of the data. *See Table 5.1 for definitions of the slab construction. †Values are for a slab-on-grade floor with a 10°F (5.6°C) slab temperature. ‡Values are for a slab-on-grade floor with a 10°F (5.6°C) slab temperature. §Values are for a slab-on-grade floor with a 10°F (5.6°C) slab temperature. ¶Values are for a slab-on-grade floor with a 10°F (5.6°C) slab temperature. ††Values are for a slab-on-grade floor with a 10°F (5.6°C) slab temperature. †††Values are for a slab-on-grade floor with a 10°F (5.6°C) slab temperature. ††††Values are for a slab-on-grade floor with a 10°F (5.6°C) slab temperature. †††††Values are for a slab-on-grade floor with a 10°F (5.6°C) slab temperature.

STEP 3: Perimeter Heat Loss ("UA" perimeter)

Heat loss coefficient (F) = 0.36 BTU/hr °F ft

Length of building perimeter (P) = 127.0 ft

"UA" perimeter = F x P = 46 BTU/hr °F

Farnsworth House

UA_{ref}

Building Element	U-value	Area	U x Area	Description
Orientation	BTU/hr °F ft ²	ft ²	BTU/hr °F	
South	1.124	384	432	Walls, Doors and Windows
			0	
East	1.124	192	216	Walls, Doors and Windows
			0	
North	1.124	384	432	Walls, Doors and Windows
			0	
West	1.124	192	216	Walls, Doors and Windows
			0	
Ceiling/Roof	0.150	1152	182	
			0	
Floor	0.112	1152	129	
			0	
UA conduction =			1606	BTU/hr °F

STEP 2: Infiltration Heat Loss ("UA" infiltration)

Volumetric Heat Capacity (AVC) = 0.216 BTU/ft³ °F

Building Volume (V) = 9216 ft³

Air Changes per Hour (ACH) = 1.30

"UA" infiltration = AVC x Volume x ACH = 216 BTU/hr °F

UA_{reference} = 1822 BTU/hr °F

Winter Hourly Heat Loss

Predicting Building Heat Loss Under Worst Case (Winter Design) Conditions:


$$Q_{\text{losses}} = UA_{\text{ref}} \times \Delta T$$

$$\text{Rate of Fuel Use} = \frac{UA_{\text{ref}} \times \Delta T}{V \times \text{Efficiency}}$$

Fuel	Heating Value (V)	Typical Efficiency (%)
No. 2 oil:	141,000 BTU/gal	75
Natural Gas	1,050 BTU/ft ³	75
Propane	2,500 BTU/ft ³	75
Electricity	3413 BTU/kW	100

Winter Hourly Heat Loss

Predicting Building Heat Loss Under Worst Case (Winter Design) Conditions:



Chicago Design Conditions
 Winter Design Temp. (97.5%) -4°F
 HDD65°F 6013
 Summer Design Temp. (2.5%) 89/74

Furnace (heating plant capacity) Sizing:
 $Q_{losses} = UA_{ref} \times \Delta T = 1822 \text{ BTU/hr } ^\circ\text{F} \times (68^\circ - (-4^\circ))$
 $Q_{losses} = 131,184 \text{ BTU/hr}$

Rate of Fuel Consumption:
 Rate of Fuel Use = 131,184 BTU/hr / (1050 BTU/ft³ x .75)
 Rate of Fuel Use = **167 ft³/hr** (natural gas)

Seasonal Heating Calculations

Predicting Annual Purchased Heating

$$E = \frac{(UA) (\text{DegreeDays}) (24 \text{ hr})}{(\text{AFUE}) (V)}$$

Some Typical Values for Annual Fuel Utilization Efficiency:

Type of Furnace	AFUE
Natural Gas, natural-draft w/standing pilot	64.5%
Natural Gas, fan-assisted combustion	80.0%
Oil, standard w/improved heat transfer	76.0%

Seasonal Heating Calculations

Predicting Annual Purchased Heating

$$E = \frac{(1822 \text{ BTU/hr } ^\circ\text{F}) (6013 \text{ } ^\circ\text{F days}) (24 \text{ hrs/day})}{(.80) (1,050 \text{ BTU/ft}^3)}$$

$$E = 313,020 \text{ ft}^3 \text{ natural gas per year}$$

Farnsworth House Heat Transfer Coefficient (UA conduction)

AS BUILT

Building Element Orientation	Element	U-value BTU/hr ft ² °F	Area ft ²	U x Area BTU/hr °F	Description
South	Walls, Doors and Windows	1.124	384	432	
				0	
East	Walls, Doors and Windows	1.124	192	216	
				0	
North	Walls, Doors and Windows	1.124	384	432	
				0	
West	Walls, Doors and Windows	1.124	192	216	
				0	
Ceiling/Roof		0.158	1152	182	
				0	
Floor		0.112	1152	129	
				0	
UA conduction =				1606	BTU/hr °F

STEP 2: Infiltration Heat Loss ("UA" infiltration)

Volumetric Heat Capacity (Air) 0.018 BTU/ft³ °F
 Building Volume (ft³) 9216 ft³
 Air Changes per Hour (ACH) 1.30 ACH

"UA" infiltration = VHC x Volume x ACH 216 BTU/hr °F

UA reference 1822 BTU/hr °F

Farnsworth House Heat Transfer Coefficient (UA conduction)

AFTER RENOVATIONS

Building Element Orientation	Element	U-value BTU/hr ft ² °F	Area ft ²	U x Area BTU/hr °F	Description
South	Walls, Doors and Windows	0.038	384	15	
				0	
East	Walls, Doors and Windows	0.038	192	7	
				0	
North	Walls, Doors and Windows	0.038	384	15	
				0	
West	Walls, Doors and Windows	0.038	192	7	
				0	
Ceiling/Roof		0.158	1152	182	
				0	
Floor		0.112	1152	129	
				0	
UA conduction =				355	BTU/hr °F

STEP 2: Infiltration Heat Loss ("UA" infiltration)

Volumetric Heat Capacity (Air) 0.018 BTU/ft³ °F
 Building Volume (ft³) 9216 ft³
 Air Changes per Hour (ACH) 0.51 ACH

"UA" infiltration = VHC x Volume x ACH 85 BTU/hr °F

UA reference 439 BTU/hr °F

439 BTU/hr °F
Vs.
1822 BTU/hr °F
76% improvement

Balance Point Temperature

Thermal Equilibrium between Inside and Outside

$$Q_{in} = Q_{out}$$

$$Q_{gains} = Q_{losses}$$

$$Q_{gains} = Q_{free} + Q_{purchased} = Q_{losses}$$

$Q_{free} = \text{people} + \text{lights} + \text{equipment (and sun!)}$
 $Q_{purchased} = \text{purchased heat (boiler, furnace, etc.)}$

$$Q_{losses} = UA \times (T_{in} - T_{outside}) = UA \times \Delta T$$

Balance Point Temperature:
 $T_{balance \text{ point}} = T_{in} - Q_{gains} / UA$

Determine Internal Loads
PEOPLE • LIGHTS • EQUIPMENT
 ENVELOPE • INFILTRATION

F.3 ESTIMATING SUMMER HEAT GAINS MEEB 10th, pg. 1610

TABLE F.3 Approximate Summer Heat Gains from Occupants, Equipment, Lighting, and Envelope

Function	Area per Person ^a		Sensible Heat Gain (Btu/h ft ² of Floor Area)			Sensible Heat Gain (W/m ² of Floor Area)		
	ft ²	m ²	People ^b	Equipment	Total	People ^b	Equipment	Total
			0.0-1.1	1.5-1.8	4.1-7.3	1.2-1.8	4.3-10.7	
Office, U.S. ^c	180-100	16.7-9.8	1-1.6	2.2-4.2	3.2-5.8	3-5	7-13.1	10-18.1
Office, Europe ^d	100-20	9.3-1.9	2.3-11.5	0-0.6	2.3-11.5	7.3-36.3	0-2.0	7.3-38.3
School, elementary, U.S.	38-9.0	3.5-0.8	0-0.6	3.8-6.6	12-25.2	0-0.0	12.0-25.2	
School, secondary	150-100	13.9-9.4	1.7-2.6	0-0.6	1.7-2.6	5.4-8.2	0-0.0	5.4-10.2
Health care								
Sleeping (hospital)	240	22.3	0.9	0.6 ^e	1.5	2.8	2.0 ^e	4.8
Inpatient (clinic)	120	11.1	1.9	0.6 ^e	1.9+	6.0	0.6 ^e	6.0+
Ambulatory (outpatient)	15	1.4	14.0	—	14.0	44.2	—	44.2
Standing space, concentrated use	15-7	1.4-0.7	21.0-45.1	0-0.5	21.0-45.1	60.3-142.0	0-1.6	60.3-143.6
Restaurants ^f								
Fast food dining area	15	1.4	17	3.4	25.4	53.6	10.3	64.3
Kitchen, refrigeration								
Ski-down dining area	25	2.3	10.2	5.1	17.3	32.2	16.1	48.1
Kitchen, refrigeration								
Kitchens, refrigeration								
Other sales floors	50-30	4.7-2.8	6.3-10.1	3.4	9.7-13.0	19.9-23.1	10.7	26.6-33.8
Warehouses, great floor	60-30	5.6-4.7	5.3-6.1	3.4	8.7-9.7	18.7-19.0	10.7	21.4-30.6
Shipping (airline, Europe) ^g								
Warehouses	1000-300	27.9-18.6	0.8-1.2	3.2	3.5-4.5	10	1.0-4.0	11.0-18.0
Hotels, nursing homes	300-200	27.9-18.6	0.8-1.2	3.4	4.2-4.6	2.5-3.8	10.7	13.3-18.5
Apartments ^h	300-200	27.9-18.6	0.8-1.2	See notes	See notes	2.5-3.8	See notes	See notes

Determine Internal Loads
 PEOPLE • **LIGHTS** • EQUIPMENT
 ENVELOPE • INFILTRATION

MEEB 10th, pg. 1610

Part B. Internal Heat Sources—Electric Lighting

Function	Sensible Heat Gain ^a (Btu/h ft ² of Floor Area)			Sensible Heat Gain ^a (W/m ² of Floor Area)		
	DF<1	1<DF<4	DF=4	DF<1	1<DF<4	DF=4
Office	5.1	2.0	0.5	15.1	6.3	1.6
School, elementary	6.3-6.8	2.5-2.7	0.6-0.7	19.9-21.5	7.9-8.5	1.9-2.2
School, secondary, college	6.3-6.8	2.5-2.7	0.6-0.7	19.9-21.5	7.9-8.5	1.9-2.2
Health care						
Sleeping (hospital)	6.8	2.7	0.7	21.5	8.5	2.2
Inpatient (clinic)	6.8	2.7	0.7	21.5	8.5	2.2
Ambulatory	3.8	1.5	0.4	12.0	4.7	1.3
Restaurants	6.3	2.5	0.6	19.9	7.9	1.9
Merchandise	5.1-6.8	2.0-2.7	0.5-0.7	16.1-21.5	6.3-8.5	1.6-2.2
Warehouse	2.4	1.0	0.2	7.6	3.2	0.6
Hotels, nursing homes	6.8	2.7	0.7	21.5	8.5	2.2
Apartments ^b	Up to 6.8	Up to 2.7	Up to 0.7	Up to 21.5	Up to 8.5	Up to 2.2