

I. ENVH 557 Exposure Controls

M. Yost, Winter 2006

KEY- Problem set II (due Thurs. Feb 2, 2006)

- Standard conditions in ventilation are:  $T = 70^{\circ}\text{F}$ ,  $P = 29.9\text{in Hg}$ , air density =  $0.075\text{ lbm/ft}^3$ . Express the temperature in degrees C, R and K. Express the pressure in the following units: mm Hg, inches of water, atm and psi. What change in temperature or pressure is needed to make a change in the air density of at least 5%?

ANS:  $70^{\circ}\text{F} + 459.7 = 529.7^{\circ}\text{R}$ ;  $(70^{\circ}\text{F}-32) * 5/9 = 21.1^{\circ}\text{C}$ ;  $(70^{\circ}\text{F}-32) * 5/9+273 = 294.1^{\circ}\text{K}$   
 $29.9\text{ "Hg} = 760\text{ mmHg} = 1\text{ Atm} = 407\text{ "H}_2\text{O}$

Air density changes proportionally to absolute pressure and inversely with absolute temperature. This is expressed by the density factor =  $d = (P/407) * 529.7 / (459.7 + T)$  where P is pressure in "H<sub>2</sub>O and T is temperature in °F. To get a 5% change in the density factor, temperature and pressure would be above or below the range below:

Problem 1b	High	Low
Temp5%	98	44
Press5%	428	386

- Air is flowing at a velocity of  $3500\text{ft/min}$  (FPM) through a circular duct section 15 inches in diameter and 12 ft long. Assume standard conditions. What is the volume flow rate? What is the mass flow rate?

ANS: the volume flow rate in CFM =  $Q = (\text{duct area}) * \text{velocity}$ ; mass flow rate is =  $m_{\text{dot}} = Q * \text{density}$ . At standard conditions the air density is  $0.075\text{ lbm/cuft}$ .

Therefore:

Problem 2		
FPM	Duct_vel	3500
lb/cuft	Air_density	0.075
Inches	Duct_diam	15
Sqft	Duct_area	1.23
<b>CFM</b>	<b>Q</b>	<b>4295.15</b>
<b>lbm/min</b>	<b>m_dot</b>	<b>322.14</b>

- At the end of the 15-inch section above, the duct diameter reduces to 9 inches and after 18 feet at this diameter, changes to a 9" x 12" rectangular duct section 12 feet long. Draw a sketch of this duct network and label each section (a,b,c, etc.). What is the new velocity, volume flow rate and Re number in each section of duct? (HINT: to calculate Re for a non-circular duct, you need to find the equivalent hydraulic diameter of the duct section.)

ANS: The volume flow rate is the velocity times the area or  $Q = VA = 3500 * 1.227 = 4295\text{ CFM}$ . The mass flow  $0.075\text{ lbs/cuft} * 4295\text{ CFM} = 322\text{ lbs/min}$ . These terms remain constant in a serial flow duct section. Since density is constant, we can use Q above to compute the velocity into each section. The table below gives the calculations for each duct section. (Note the diameter in yellow is the hydraulic diameter which is =  $4 * \text{area} / \text{perimeter}$ . Also, the area of duct section 3 is just the geometric area (length \* width), it is NOT computed from the hydraulic diameter). We see that section 2 has the highest Reynolds number, therefore making that section laminar will make all others laminar.

Note that Reynolds number scales linearly with velocity, so we can use a simple proportion to find the velocity that gives  $Re = 2000$ . Setting the velocity to 26 FPM in section 2 gives  $Re \sim 2000$  (the maximum velocity condition for laminar flow).

Kinematic Viscosity of air		Duct Section #3		
cm <sup>2</sup> /s	Ft <sup>2</sup> /s	width	length	D <sub>hydro</sub>
0.15083	1.6235E-04	9	12	10.2857143

  

Problem 3							
section	Dia(in)	SqFt	Dia (ft)	Velocity	CFM	lb/min	Re
1	15	1.22718463	1.250	3500	4295	322	449133
2	9	0.44178647	0.750	9722	4295	322	748554
3	10.29	0.75	0.857	5727	4295	322	503926

**For laminar flow, we choose section 2 as limiting case; assume a maximum Re of 5000**

2	9	0.44178647	0.750	64	28	2	4928
---	---	------------	-------	----	----	---	------

4. Air is moving through a pipe at a volume flow rate of 2000 CFM and a temperature of 70°F. If the temperature increases to 95°F, what is the new volume flow rate, assuming the barometric pressure (1 atm) remains constant? What is the new mass flow rate?

ANS: The problem is solved directly if we remember the mass flow stays constant while the volume flow rate changes with changes in density, so  $(\rho_1) Q_1 = (\rho_2) Q_2$

Problem 4	Temp_1	Temp_2	Temp_1R	Temp_2R
	70	95	529.67	554.67
Q1 (CFM)	Density_1	m1 lbs/min	Density_2	Q_2 (CFM)
2000	0.075	150	0.07162	2094.4

5. The velocity pressure of air in a duct is 1.5 in w.g. What is the velocity?

ANS: Assume standard conditions, so  $V = 4005 \cdot \sqrt{P_v}$

Problem 5	Pv	Velocity
	1.5	4905.10

6. The static pressure in a 5-inch diameter duct is measured as -2.5 in w.g. The total pressure (or stagnation pressure) is -1.3 in w.g. What is the velocity of the air in the duct? What is the volume flow rate?

ANS: Use the relationship  $P_t = P_s + P_v$  to find the velocity pressure  $P_v$ , then compute the velocity from the relationship in problem #5. The volume flow rate  $Q$  is then computed in the same manner as in problem 3.

**Problem 6**

Pt	Ps	Pv	Dia(in)	SqFt	Velocity	CFM
-1.3	-2.5	1.2	5	0.1364	4387.3	598

7. Assume a ventilation system is operating with a 4-inch diameter duct. At what volume flow rate (cfm) will the upper limit of laminar flow be reached?

ANS: This problem is similar to problem 3, assume  $Re$  of  $\sim 2000$  for laminar flow.

Problem 7	Dia(in)	SqFt	Dia (ft)	Velocity	CFM	Re
	4	0.08726646	0.333	58.45	5	2000